



2812

---

## CERTIFICATE OF BUILDING AIR PERMEABILITY

---

This is to certify that

**Bosch Warehouse & Offices Zone B Plot 2,  
North Kettering Business Park**

**Tested for Building Air Permeability on 3<sup>rd</sup> November 2005  
Measured in accordance with CIBSE TM23: 2001  
Achieved a performance of**

**1.03 m<sup>3</sup>/hr/m<sup>2</sup>**

Certificate Number: **000369-2**

Awarded by: **Andrew Lane** BSc (hons) CEng MCBSE  
Director CPC Limited

Date: **4<sup>th</sup> November 2005**

SIGNED:

*Andrew Lane*

---

**CONSTRUCTION PERFORMANCE CONSULTING LIMITED**

• E: [sales@cpcluk.com](mailto:sales@cpcluk.com)  
[www.cpcluk.com](http://www.cpcluk.com)

• 7/8 Simmonds Buildings, Bristol Road  
Hambrook, Bristol BS16 1RY

T: 0117 957 0670 F: 0117 956 1007  
Mobile: 07766 917877

• Ashbocking Hall Farm, Church Road, Ashbocking  
Ipswich, Suffolk IP6 9LG

T/F: 01473 890135  
Mobile: 07768 680371